



CITY MANAGER'S OFFICE
CITY OF NEWARK

220 South Main Street · Newark, Delaware 19711
302.366.7000 · Fax 302.366.7035 · www.newarkde.gov

September 28, 2023

CONTRACT NO. 23-16

ADDENDUM #2

1. PROJECT INFORMATION

Name: Field Operations Complex Perimeter Fencing Replacement
Owner: City of Newark, Delaware
Contract Number: 23-16
Date of Addendum: September 28, 2023
Pre-Bid Meeting Date: 10:00 a.m., Tuesday, September 19, 2023
Questions Deadline: 12:00 p.m., Friday, September 22, 2023
Bid Submission Deadline: 2:00 p.m., Tuesday, October 3, 2023

2. NOTICE TO BIDDERS

- A. The Bidder shall acknowledge receipt of this addendum with their submitted proposal. Failure to do so may disqualify the Bidder.
- B. The date for questions and receipt of bids remains unchanged by this addendum.
- C. This addendum shall serve to answer questions submitted to date for this contract.

3. QUESTIONS

Q1. The written specification mentions the fence having a bottom rail, but the detail shows a bottom tension wire. Would you be able to confirm if the fence should have a bottom rail or bottom tension wire?

A1. The fence shall have a bottom tension wire.

Q2. Is 2.5" Line Post and 3" Terminal Post acceptable?

A2. No, wind load needs to be considered since we are adding slats. Therefore, the 2.5" line posts and 3" terminal posts would be undersized.

END OF ADDENDUM #2